

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-0067:131 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd,
Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Model CXL fire alarm control unit. Proprietary unit; automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. Modules included in this listing:

CXM-1	Modem interface module
CXC-1, -2	Central processing module
CXP-1	Memory module
CXB-1	Motherboard module/card cage
CXA-1	Power supply/front panel assembly
EBX-1	Single card cage backbox
EDX-1	Single card cage door
CXL-G	Graphic Interface
D2300CP	Fiber Optic Repeater

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number and UL label.

APPROVAL: Listed as a proprietary receiving service control unit for use with Model XL3 (CSFM Listing No.7165-0067:104 and 7170-0067:151) or Model MXL (CSFM Listing No. 7165-0067:144) as data gathering panels and separately listed compatible initiating and indicating devices. RC-319 printer and RC-318 CRT and keyboard are intended to be in the same room as the CXL.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager